



Andersen Corporation
100 4th Avenue North
Bayport, MN 55003-1096

Mfr#: 129

TEL:

<i>Product No.</i>	<i>Product Name</i>	<i>Standard</i>	<i>Rating</i>	<i>Wide</i>	<i>High</i>	<i>Test Report #</i>	<i>CertDate</i>	<i>ExpDate</i>
129-H-1041.00	100 Series Non-Reinforced Mullion - Various Horizontal and Vertical Non-Reinforcing Mullions-Contact manufacturers for DPcharts	AAMA 450-10	DP Varies-Size 96" Max Span -72" Max Tributary Width, Complies (Option 1 & 3)	72" Max Tributary Width	96" Max Span	100 Series Non-Reinforced Mullion	06/26/2019	04/04/2022
129-H-1041.01	100 Series Reinforced Mullion - Various Horizontal and Vertical Non-Reinforcing Mullions-Contact manufacturers for DPcharts	AAMA 450-10	DP Varies-Size 144" Max Span -96" Max Tributary Width one-way and 72" two-way, Complies (Option 1 & 3)	96" Max Tributary Width for one-way and 72" Max Trib Width for two-way	144" Max Span	100 Series Reinforced Mullion	06/26/2019	09/18/2028

WDMA and AMS HEREBY CERTIFY that the aforesaid Company ("Licensee"), at its participating manufacturing plant(s), is licensed to use the WDMA Registered Hallmark on product lines that have been manufactured in accordance with the indicated standards. It is further certified that the plant(s), facilities, quality control procedures, methods and processes of Licensee have been inspected, and are subject to regular follow-up inspection and test. It is further certified that samples of the products set forth above were tested and found to comply with the standards.

By: *John McFee* **John McFee, VP of Certification Programs, WDMA Hallmark**

By: *Lucas L. Wenzel* **Lucas L. Wenzel, Authorized Representative, AMS**

Program Sponsor:
Window and Door Manufacturers Assoc
330 N. Wabash Avenue, Suite 2000
Chicago, IL 60611
TEL (312)673-4828 www.wdma.com

Program Administrator:
Administrative Management Services, Inc.
205 West Main Street, PO Box 730
Sackets Harbor, NY 13685
TEL (315)646-2234 staff@amscert.com