



Total Quality. Assured.

### SUMMARY TEST REPORT

FOR: Andersen Corporation  
100 Fourth Avenue North  
Bayport, MN 55003

Report Number: I3056.03-201-47  
Test End Date: 04/27/2018  
Report Date: 05/01/2018  
Test Record Retention End Date: 04/27/2022

SERIES TESTED: Single Hung  
MODEL TESTED: 100 Series Single Hung Window/100SHS2666 IG

<b>NAFS-17/-11/-08</b>		Class LC-PG50 Size Tested 29.5 x 77.5 in. DP +50/-50 psf*
<b>Test</b>	<b>Results Summary</b>	
Operating Force	125 N (28 lbf)	
Resistance to Air Infiltration	0.07 cfm/ft <sup>2</sup> (ASTM E283)	
Resistance to Water Penetration	Pass at DP50 (ASTM E547)	
Resistance to Structural Loading	Pass at DP +50/-50 (ASTM E330)	
Forced Entry Resistance	Pass (ASTM F 588)	

<b>CAN/CSA A440-00</b> , Evaluation to the prescriptive requirements were not performed	
<b>Test</b>	<b>Rating</b>
Operating Ease	125 N (28 lbf)
Air Tightness	A2
Water Tightness	B3
Wind Load Resistance	C3
Blow-Out	C3
Forced Entry Resistance	F10
Screen Push-out	S1

<b>REFERENCE:</b>	See ATI Report No. I3056.01-201-47 and I3056.02-201-47 for complete test results. *Reference Intertek B&C Report No. I3056.01-201-47, dated 02/19/19 for complete Gateway test specimen description and test results.
-------------------	--

A copy of this report will be retained by Intertek-ATI for a period of four years. This report is the exclusive property of the client named herein and is applicable to the sample tested. Results obtained are tested values and do not constitute an opinion or endorsement by this laboratory.

INTERTEK-ATI

INTERTEK-ATI

Tony D. Gavin  
Technician

Daniel A. Johnson  
Director of Regional Operations

