



Total Quality. Assured.

849 Western Avenue North  
St. Paul, Minnesota 55117

Telephone: 651-636-3835  
Facsimile: 717-764-4129  
www.intertek.com/building

**SUMMARY TEST REPORT**

FOR: Andersen Corporation  
100 Fourth Avenue North  
Bayport, Minnesota 55003-1096

Report Number: I0721.03-201-47  
Test End Date: 02/07/2018  
Report Date: 02/15/2018  
Test Record Retention End Date: 02/07/2022

SERIES TESTED: 100 Series Picture Window  
MODEL TESTED: 100REC6680 IG

**NAFS-17/-11/-08** Class LC-PG50 Size Tested 77.5 x 95.5 in. DP+50/-50 psf

**Test**

**Results Summary**

Operating Force	N/A
Resistance to Air Infiltration	<0.05 L/s/m <sup>2</sup> (<0.01 cfm/ft <sup>2</sup> ) (ASTM E283)
Resistance to Water Penetration	Pass at DP50 (ASTM E547)
Resistance to Structural Loading	Pass at DP+50/-50 (ASTM E330)
Forced Entry Resistance	Pass (ASTM F 588)

**CAN/CSA A440-00**, Evaluation to the prescriptive requirements were not performed

**Test**

**Rating**

Operating Ease	(N/A)
Air Tightness	Fixed
Water Tightness	B3
Wind Load Resistance	C5
Blow-Out	C3
Forced Entry Resistance	Pass (ASTM F 588)

**REFERENCE:**

See Intertek-ATI Report No. I0721.01-201-47 and I0721.02-201-47 for complete test results.

A copy of this report will be retained by Intertek-ATI for a period of four years. This report is the exclusive property of the client named herein and is applicable to the sample tested. Results obtained are tested values and do not constitute an opinion or endorsement by this laboratory.

**ARCHITECTURAL TESTING, INC**

**ARCHITECTURAL TESTING, INC**

Karl A. Lips-Eakins  
Senior Technician

Daniel A. Johnson  
Director - Regional Operations

