



**SUMMARY TEST REPORT**

FOR: Andersen Corporation  
100 Fourth Avenue North  
Bayport, MN 55003

Report Number: G2190.03-201-44  
Test End Date: 08/17/2016  
Report Date: 08/29/2016  
Test Record Retention End Date: 08/17/2020

SERIES TESTED: Clad Wood Awning Window  
MODEL TESTED: A-Series Awning Window/AAN4040 IG

**NAFS-08/-11** Class LC-PG50 Size Tested 47.3 x 47.3 in. DP +50/-50

**Test**

**Results Summary**

Operating Ease	22 N (5 lbf)
Resistance to Air Infiltration	<0.01 cfm/ft <sup>2</sup> (ASTM E283)
Resistance to Water Penetration	Pass at DP50 (ASTM E547)
Resistance to Structural Loading	Pass at DP +50/-50 (ASTM E330)
Forced Entry Resistance	Pass (ASTM F 588)

**CAN/CSA A440-00**, Evaluation to the prescriptive requirements were not performed

**Test**

**Rating**

Operating Ease	22 N (5 lbf)
Air Tightness	A3
Water Tightness	B3
Wind Load Resistance	C3
Blow-Out	C3
Forced Entry Resistance	F10

**REFERENCE:**

See ATI Report No. G2190.01 -201-44, and G2190.02-201-44 for complete test results.

A copy of this report will be retained by Intertek-ATI for a period of four years. This report is the exclusive property of the client named herein and is applicable to the sample tested. Results obtained are tested values and do not constitute an opinion or endorsement by this laboratory.

**INTERTEK-ATI**

**INTERTEK-ATI**

Tony D. Gavin  
Technician

Daniel A. Johnson  
Director of Regional Operations