

SUMMARY TEST REPORT

FOR: Andersen Corporation
100 Fourth Avenue North
Bayport, MN 55003

Report Number: M2398.02-201-47-R0
Test End Date: 4/15/21
Report Date: 3/15/22
Test Record Retention End Date: 4/15/25

Series Model:	A-Series Contemporary Frenchwood Hinged Door-Outswing / FW OCD33100A
----------------------	--

Specification/Standards:	Rating/Results
NAFS 17, 11	Class LC-PG45 Size Tested 38.1 x 119.5 in. DP +45/-55 psf
CSA A440S1-19, 17	Class LC-PG45 Size Tested 968 x 3035 mm DP+2160/-2640 Pa Resistance to Water Penetration Test Pressure: 330 Pa Canadian Air Infiltration/Exfiltration Level = A2

Test	Results Summary
Air Infiltration per ASTM E283:	0.10 cfm/ft ² (0.50 L/s/m ²)
Air Exfiltration per ASTM E283:	0.14 cfm/ft ² (0.70 L/s/m ²)
Operating Force to Latch:	4 lbf (18 N)
Operating Force of locks:	5 lbf (22 N)
Forced Entry Resistance per AAMA 1304	Pass, 300 lb. point load
Reference:	See Intertek B&C Report No. M2398.01-201-47-R0 for complete test results.

A copy of this report will be retained by Intertek B&C for a period of four years. This report is the exclusive property of the client named herein and is applicable to the sample tested. Results obtained are tested values and do not constitute an opinion or endorsement by this laboratory.

For INTERTEK B&C:

COMPLETED BY: Karl Lips
Senior Technician –
Building & Construction

TITLE:

SIGNATURE:

DATE: 03/23/22

REVIEWED BY: Daniel Johnson
Director, Regional
Operations

TITLE:

SIGNATURE:

DATE: 03/23/22