

## SUMMARY TEST REPORT

FOR: Andersen Corporation  
100 Fourth Avenue North  
Bayport, MN 55003

Report Number: N2671.02-201-44-R1  
Test End Date: 02/02/2022  
Revised Report Date: 04/05/2022  
Test Record Retention End Date: 02/02/2026

<b>Series Model:</b>	A-Series Contemporary Frenchwood Hinged Patio Door – Outswing FWOCD64611AP
----------------------	---

Specification/Standards:	Rating/Results
NAFS 17, 11	Class LC-PG45 Size Tested 75.3" x 82.4" DP+45/-45
CSA A440S1-19, 17	Class LC-PG45 Size Tested 1911 mm x 2092 mm DP +2160/-2160 Pa Resistance to Water Penetration Test Pressure: 330 Pa Canadian Air Infiltration/Exfiltration Level = A3

Test	Results Summary
Air Infiltration per ASTM E283:	0.2 L/s/m <sup>2</sup> (0.04 cfm/ft <sup>2</sup> )
Air Exfiltration per ASTM E283:	0.6 L/s/m <sup>2</sup> (0.12 cfm/ft <sup>2</sup> )
Force to latch:	13 N (3 lbf)
Forced Entry Resistance per AAMA 1304:	Pass
Reference:	See Intertek B&C Report No. N2671.01-201-44-R1 for complete test results.

A copy of this report will be retained by Intertek B&C for a period of four years. This report is the exclusive property of the client named herein and is applicable to the sample tested. Results obtained are tested values and do not constitute an opinion or endorsement by this laboratory.

For INTERTEK B&C:

<b>COMPLETED BY:</b>	Dan Wadzinski Project Manager – Building & Construction	<b>REVIEWED BY:</b>	Daniel A. Johnson Director – Regional Operations
<b>TITLE:</b>		<b>TITLE:</b>	
<b>SIGNATURE:</b>		<b>SIGNATURE:</b>	
<b>DATE:</b>	04/05/22	<b>DATE:</b>	04/05/22

DW: daj/wma

REVISION #	DATE	PAGES	REVISION
0	03/24/22	N/A	Original Report Issue
1	04/05/22	1	Revised report. Report revised to correct product name.