



SUMMARY TEST REPORT

FOR: Eagle Window & Door, Inc.
2045 Kerper Boulevard
Dubuque, Iowa 52001

Report Number: D1787.03-201-44
Test End Date: 10/01/2013
Report Date: 11/30/2013
Test Record Retention End Date: 10/01/2017

SERIES TESTED: 2080 E-Series Hinged Patio Door Sidelight - Outswing

NAFS-11	Class CW-PG50 622 x 2438 (24 x 96)-SLT
NAFS-08	Class CW-PG50 622 x 2438 (24 x 96)-SLT
Test	Results Summary
Resistance to Air Infiltration	<0.01 cfm/ft ² (ASTM E283)
Resistance to Water Penetration	Pass at DP50 (ASTM E547)
Resistance to Structural Loading	Pass at DP50 (ASTM E330)
Forced Entry Resistance	Pass at Grade 10 (ASTM F588)

CAN/CSA A440-00, Evaluation to the prescriptive requirements were not performed

Test	Rating
Air Tightness	Fixed
Water Tightness	B4
Wind Load Resistance	C5
Blow-Out	C3

REFERENCE:	See ATI Report No. D1787.01-201-44 and D1787.02-201-44 for complete test results.
-------------------	---

A copy of this report will be retained by ATI for a period of four years. This report is the exclusive property of the client named herein and is applicable to the sample tested. Results obtained are tested values and do not constitute an opinion or endorsement by this laboratory.

ARCHITECTURAL TESTING, INC

ARCHITECTURAL TESTING, INC

Eric J. Schoenthaler
Project Manager

Daniel A. Johnson
Director - Regional Operations

849 Western Avenue North
St. Paul, MN 55117
Phone: 651-636-3835
Fax: 651-636-3843
www.archtest.com