



SUMMARY TEST REPORT

FOR: Andersen Corporation, E-Series
2045 Kerper Boulevard
Dubuque, Iowa 52001

Report Number: G4237.03-201-44
Test End Date: 10/31/2016
Report Date: 01/18/2017
Test Record Retention End Date: 10/31/2020

SERIES TESTED: E-Series Hinged Patio Door In-swing
MODEL TESTED: 3486 Hinged Patio - Inswing (SP4) (X)

NAFS-08/-11	Class LC-PG45 Size Tested 40.0 x 102.0 in. DP +50/-65
Test	Results Summary
Resistance to Air Infiltration	0.03 cfm/ft ² (ASTM E283)
Resistance to Water Penetration	Pass at DP45 (ASTM E547)
Resistance to Structural Loading	Pass at DP50 (ASTM E330)
Forced Entry Resistance	Pass (AAMA 1304)

CAN/CSA A440-00 , Evaluation to the prescriptive requirements were not performed	
Test	Rating
Air Tightness	A3
Water Tightness	B3
Wind Load Resistance	C3
Blow-Out	C3
Forced Entry Resistance	F10

REFERENCE:	See Intertek-ATI Report No. G4237.01-201-44 and G4237.02-201-44 for complete test results.
-------------------	--

A copy of this report will be retained by Intertek-ATI for a period of four years. This report is the exclusive property of the client named herein and is applicable to the sample tested. Results obtained are tested values and do not constitute an opinion or endorsement by this laboratory.

ARCHITECTURAL TESTING, INC

ARCHITECTURAL TESTING, INC

Karl A. Lips-Eakins
Senior Technician

Daniel A. Johnson
Director - Regional Operations