



SUMMARY TEST REPORT

FOR: Eagle Window & Door, Inc.
2045 Kerper Boulevard
Dubuque, Iowa 52001

Report Number: D4334.03-201-44
Test End Date: 04/04/2014
Report Date: 04/04/2014
Test Record Retention End Date: 04/04/2018

SERIES TESTED:

3280 Hinged Patio Door – Outswing Single SP1M1

NAFS-08/-11

Class LC-PG60 Size Tested 927 x 2421 mm (36.5 x 95.3 in.)-SHD

Test

Force to Latch
Resistance to Air Infiltration
Resistance to Water Penetration
Resistance to Structural Loading
Forced Entry Resistance

Results Summary

Pass, 53 N (12.0 lbf) max.
0.08 cfm/ft² (ASTM E283)
Pass at DP60 (ASTM E547)
Pass at DP60 (ASTM E330)
Pass, (AAMA 1304)

CAN/CGSB-82.1-M89, Evaluation to the prescriptive requirements were not performed

Test

Air Tightness
Water Tightness
Wind Load Resistance
Blow-Out

Rating

A3
B4
C3
C3

REFERENCE:

See ATI Report No. D4334.01-201-44 and D4334.02-201-44
for complete test results.

A copy of this report will be retained by ATI for a period of four years. This report is the exclusive property of the client named herein and is applicable to the sample tested. Results obtained are tested values and do not constitute an opinion or endorsement by this laboratory.

ARCHITECTURAL TESTING, INC

ARCHITECTURAL TESTING, INC

Eric J. Schoenthaler
Project Manager

Daniel A. Johnson
Director - Regional Operations

849 Western Avenue North
St. Paul, MN 55117
Phone: 651-636-3835
Fax: 651-636-3843
www.archtest.com