



**SUMMARY TEST REPORT**

FOR: Andersen/Eagle Window & Door  
2045 Kerper Boulevard  
Dubuque, Iowa 52001

Report Number: E0255.03-201-44  
Test End Date: 10/01/2014  
Report Date: 10/02/2014  
Test Record Retention End Date: 10/01/2018

SERIES TESTED: 6780 Series 05 Radius Outswing French Door  
MODEL TESTED Aluminum Clad Wood Round-Top Double Outswing Hinged Glass Door (XX)

<b>NAFS-08/-11</b>	Class LC-PG60 2007 x 2438 (72 x 96)-SHD
<b>Test</b>	<b>Results Summary</b>
Force to Latch	Pass, 31 N (7 lbf) max.
Resistance to Air Infiltration	0.03 cfm/ft <sup>2</sup> (ASTM E283)
Resistance to Water Penetration	Pass at DP60 (ASTM E547)
Resistance to Structural Loading	Pass at DP60 (ASTM E330)
Forced Entry Resistance	Pass (AAMA 1304)

**CAN/CSA A440-00**, Evaluation to the prescriptive requirements were not performed

<b>Test</b>	<b>Rating</b>
Ease of Operation	31 N (7 lbf) max.
Air Tightness	A3
Water Tightness	B4
Wind Load Resistance	C3
Blow-Out	C3

<b>REFERENCE:</b>	See ATI Report No. E0255.01-201-44 and E0255.02-201-44 for complete test results.
-------------------	---

A copy of this report will be retained by ATI for a period of four years. This report is the exclusive property of the client named herein and is applicable to the sample tested. Results obtained are tested values and do not constitute an opinion or endorsement by this laboratory.

**ARCHITECTURAL TESTING, INC**

**ARCHITECTURAL TESTING, INC**

Tony D. Gavin  
Technician

Daniel A. Johnson  
Director - Regional Operations