



SUMMARY TEST REPORT

FOR: Eagle Window & Door, Inc.
 2045 Kerper Boulevard
 Dubuque, Iowa 52001

Report Number: D0705.03-201-44
 Test End Date: 11/19/2013
 Report Date: 11/29/2013
 Test Record Retention End Date: 11/19/2017

SERIES TESTED: 6080 E-Series Hinged Patio Door - Outswing with Harbor Master IG mulled to a
 3080 E-Series Hinged Patio Door Sidelight - Outswing with Harbor Master IG

NAFS-11	Class LC-PG65 1830 x 2421 (72 x 95)-SHD
	Class LC-PG65 927 x 2421 (36 x 95)-FD
	Class LC-PG65 927 x 2421 (36 x 95)-SLT
NAFS-08	Class LC-PG65 1830 x 2421 (72 x 95)-SHD
	Class LC-PG65 927 x 2421 (36 x 95)-FD
	Class LC-PG65 927 x 2421 (36 x 95)-SLT
AAMA 450	Class LC-PG65 - 95.31" Span x 56.0" Tributary Width - MA Rein Mull - Vertical
Test	Results Summary
Resistance to Air Infiltration	<0.01 cfm/ft ² (ASTM E283)
Resistance to Water Penetration	Pass at DP65 (ASTM E547)
Resistance to Structural Loading	Pass at DP65 (ASTM E330)
Forced Entry Resistance	Pass (AAMA 1304)
	Pass at Grade 10 (ASTM F588)

CAN/CGSB-82.1-M89, Evaluation to the prescriptive requirements were not performed

Test	Rating
Air Tightness	A3
Water Tightness	B4
Wind Load Resistance	C3
Blow-Out	C3

REFERENCE: See ATI Report No. D0705.01-201-44 and D0705.02-201-44 for complete test results.

A copy of this report will be retained by ATI for a period of four years. This report is the exclusive property of the client named herein and is applicable to the sample tested. Results obtained are tested values and do not constitute an opinion or endorsement by this laboratory.

ARCHITECTURAL TESTING, INC

ARCHITECTURAL TESTING, INC

Eric J. Schoenthaler
 Project Manager

Daniel A. Johnson
 Director - Regional Operations

849 Western Avenue North
 St. Paul, MN 55117
 Phone: 651-636-3835
 Fax: 651-636-3843
 www.archtest.com