



**SUMMARY TEST REPORT**

FOR: Eagle Window & Door, Inc.  
 2045 Kerper Boulevard  
 Dubuque, Iowa 52001

Report Number: D0706.03-201-44  
 Test End Date: 11/19/2013  
 Report Date: 12/12/2013  
 Test Record Retention End Date: 11/19/2017

SERIES TESTED: 6080 E-Series Hinged Patio Door - Outswing with Harbor Master Mono mulled to a 3080 E-Series Hinged Patio Door Sidelight - Outswing with Harbor Master Mono

<b>NAFS-11</b>	Class LC-PG65 1830 x 2421 (72 x 95)-SHD
	Class LC-PG65 927 x 2421 (36 x 95)-FD
	Class LC-PG65 927 x 2421 (36 x 95)-SLT
<b>NAFS-08</b>	Class LC-PG65 1830 x 2421 (72 x 95)-SHD
	Class LC-PG65 927 x 2421 (36 x 95)-FD
	Class LC-PG65 927 x 2421 (36 x 95)-SLT
<b>AAMA 450</b>	Class LC-PG65 - 95.31" Span x 56.0" Tributary Width - MA Rein Mull - Vertical

<u>Test</u>	<u>Results Summary</u>
Resistance to Air Infiltration	0.01 cfm/ft <sup>2</sup> (ASTM E283)
Resistance to Water Penetration	Pass at DP65 (ASTM E547)
Resistance to Structural Loading	Pass at DP65 (ASTM E330)
Forced Entry Resistance	Pass (AAMA 1304)
	Pass at Grade 10 (ASTM F588)

**CAN/CGSB-82.1-M89**, Evaluation to the prescriptive requirements were not performed

<u>Test</u>	<u>Rating</u>
Air Tightness	A3
Water Tightness	B4
Wind Load Resistance	C3
Blow-Out	C3

<b>REFERENCE:</b>	See ATI Report No. D0706.01-201-44 and D0706.02-201-44 for complete test results.
-------------------	---

A copy of this report will be retained by ATI for a period of four years. This report is the exclusive property of the client named herein and is applicable to the sample tested. Results obtained are tested values and do not constitute an opinion or endorsement by this laboratory.

**ARCHITECTURAL TESTING, INC**

**ARCHITECTURAL TESTING, INC**

Eric J. Schoenthaler  
 Project Manager

Daniel A. Johnson  
 Director - Regional Operations

849 Western Avenue North  
 St. Paul, MN 55117  
 Phone: 651-636-3835  
 Fax: 651-636-3843  
 www.archtest.com