



SUMMARY TEST REPORT

FOR: Eagle Window & Door, Inc.
2045 Kerper Boulevard
Dubuque, Iowa 52004

Report Number: C6612.03-201-44
Test End Date: 04/15/2013
Report Date: 04/15/2013
Report Revision Date: 04/10/2015
Test Record Retention End Date: 04/15/2017

SERIES TESTED: E-Series Side-Hinged Door (Out-Swing)
MODEL TESTED: 6780 Hinged Patio Door – Outswing Double w/ ADA Sill

NAFS-08,-11 Class LC-PG50 Size Tested 2009 x 2413 mm (79.1 x 95.0 in.)-LW-SHD
NAFS-05 SHD LW-LC50 2009 x 2413 (79 x 95)

<u>Test</u>	<u>Results Summary</u>
Operating Ease, Force to Latch	Pass, 4 lbs
Resistance to Air Infiltration	0.02 cfm/ft ² (ASTM E283)
Resistance to Water Penetration	Limited Water (0 psf) (ASTM E331)
Resistance to Structural Loading	Pass at DP+50/-50 (ASTM E330)
Forced Entry Resistance	Pass (AAMA 1304)

CAN/CSA A440-00, Evaluation to the prescriptive requirements were not performed

<u>Test</u>	<u>Rating</u>
Operating Ease	Pass
Air Tightness	A3
Water Tightness	N/A
Wind Load Resistance	C3
Blow-Out	C3

<u>Test</u>	<u>Results Summary</u>
Impact	N/A
Pressure Cycling	N/A

REFERENCE: See Intertek-ATI Report No. C6612.01-201-44 and C6612.02-201-44 for complete test results.

A copy of this report will be retained by Intertek-ATI for a period of four years. This report is the exclusive property of the client named herein and is applicable to the sample tested. Results obtained are tested values and do not constitute an opinion or endorsement by this laboratory.

INTERTEK-ATI

INTERTEK-ATI

Karl A. Lips-Eakins
Senior Technician

Daniel A. Johnson
Director of Regional Operations