



SUMMARY TEST REPORT

FOR: Andersen E-Series/Eagle Window & Door
2045 Kerper Boulevard
Dubuque, Iowa 52001

Report Number: E0007.03-201-44
Test End Date: 09/16/2014
Report Date: 10/03/2014
Test Record Retention End Date: 09/16/2018

SERIES TESTED:
MODEL TESTED

Aluminum Clad Double Hung
4686 T7 Talon Clad Double Hung Vent
Class LC-PG30 1372 x 2591 (54 x 102)-H

NAFS-08/-11

Test

Results Summary

Force to Latch
Resistance to Air Infiltration
Resistance to Water Penetration
Resistance to Structural Loading
Forced Entry Resistance

Pass, 99 N (22 lbf) max.
0.14 cfm/ft² (ASTM E283)
Pass at DP30 (ASTM E547)
Pass at DP30 (ASTM E330)
Pass (ASTM F 588)

CAN/CSA A440-00, Evaluation to the prescriptive requirements were not performed

Test

Rating

Ease of Operation
Air Tightness
Water Tightness
Wind Load Resistance
Blow-Out
Forced Entry Resistance

Pass, 99 N (22 lbf)
A2
B4
C2
C2
F10

REFERENCE:

See ATI Report No. E0007.01-201-44 and E0007.02-201-44 for complete test results.

A copy of this report will be retained by ATI for a period of four years. This report is the exclusive property of the client named herein and is applicable to the sample tested. Results obtained are tested values and do not constitute an opinion or endorsement by this laboratory.

ARCHITECTURAL TESTING, INC

ARCHITECTURAL TESTING, INC

Tony D. Gavin
Technician

Daniel A. Johnson
Director - Regional Operations