



SUMMARY TEST REPORT

FOR: Andersen E-Series/Eagle Window & Door
2045 Kerper Boulevard
Dubuque, Iowa 52001

Report Number: F2054.02-201-44
Test End Date: 11/24/2015
Report Date: 01/20/2016
Test Record Retention End Date: 11/24/2019

SERIES TESTED: Aluminum Clad Wood Casement with Impact Glazing
MODEL TESTED: 3060 Series 11 Casement with HM Mono
NAFS-08/-11 Class CW-PG65 Size Tested 914 x 1829 mm (36.0 x 72.0 in.)-C

<u>Test</u>	<u>Results Summary</u>
Operating Force	Pass, 18 N (4 lbf) max.
Resistance to Air Infiltration	<0.01 cfm/ft ² (ASTM E283)
Resistance to Water Penetration	Pass at DP65 (ASTM E547)
Resistance to Structural Loading	Pass at DP+65/-75 (ASTM E330)
Forced Entry Resistance	Pass (ASTM F 588)

ASTM E1886 / ASTM E1996	
<u>Test</u>	<u>Results Summary</u>
Impact	No rips, tears or penetrations, Missile D, Zone 4
Pressure Cycling	DP +65/-75 psf

REFERENCE:	See ATI Report No. F2054.01-201-44 and F2042.02-201-18 for complete test results.
-------------------	---

A copy of this report will be retained by ATI for a period of four years. This report is the exclusive property of the client named herein and is applicable to the sample tested. Results obtained are tested values and do not constitute an opinion or endorsement by this laboratory.

ARCHITECTURAL TESTING, INC

ARCHITECTURAL TESTING, INC

Tony D. Gavin
Technician

Daniel A. Johnson
Director - Regional Operations