



SUMMARY TEST REPORT

FOR: Andersen E-Series/Eagle Window & Door
2045 Kerper Boulevard
Dubuque, Iowa 52001

Report Number: F2055.02-201-44
Test End Date: 11/24/2015
Report Date: 01/20/2016
Test Record Retention End Date: 11/24/2019

SERIES TESTED: Aluminum Clad Wood Casement with Impact Glazing
MODEL TESTED: 3056 Series 11 Casement with HM Mono
NAFS-08/-11 Class CW-PG65 Size Tested 914 x 1676 mm (36.0 x 66.0 in.)-C

Test

Results Summary

Operating Force
Resistance to Air Infiltration
Resistance to Water Penetration
Resistance to Structural Loading
Forced Entry Resistance

Pass, 18 N (4 lbf) max.
<0.01 cfm/ft² (ASTM E283)
Pass at DP65 (ASTM E547)
Pass at DP+65/-75 (ASTM E330)
Pass (ASTM F 588)

ASTM E1886 / ASTM E1996

Test

Results Summary

Impact
Pressure Cycling

No rips, tears or penetrations, Missile D, Zone 4
DP +65/-75 psf

REFERENCE:

See ATI Report No. F2055.01-201-44 and F2043.02-201-18 for complete test results.

A copy of this report will be retained by ATI for a period of four years. This report is the exclusive property of the client named herein and is applicable to the sample tested. Results obtained are tested values and do not constitute an opinion or endorsement by this laboratory.

ARCHITECTURAL TESTING, INC

ARCHITECTURAL TESTING, INC

Tony D. Gavin
Technician

Daniel A. Johnson
Director - Regional Operations