



SUMMARY TEST REPORT

FOR: Andersen Corporation, E-Series
2045 Kerper Boulevard
Dubuque, Iowa 52001

Report Number: G0170.03-201-44
Test End Date: 07/11/2016
Report Date: 09/22/2016
Test Record Retention End Date: 09/22/2020

SERIES TESTED: E-Series Hinged Patio Door Outswing Transom with Harbor Master IG
MODEL TESTED: 6030

NAFS-08/-11 Class LC-PG65 1829 x 914 (72 x 36)-TR DP +65/-65 psf

Test

Results Summary

Resistance to Air Infiltration
Resistance to Water Penetration
Resistance to Structural Loading
Forced Entry Resistance

<0.01 cfm/ft² (ASTM E283)
Pass at DP65 (ASTM E547)
Pass at DP +65/-65 (ASTM E330)
Pass (ASTM F588)

ASTM E1886, E1996

Test

Results Summary

Impact
Pressure Cycling

Wind Zone 4, Missile level D
DP +65/-65 psf

Dade County Testing

Test

Results Summary

TAS 202
TAS 201
TAS 203

Pass at DP +65/-65 psf
Pass (Large Missile)
Pass at +65/-65 psf

REFERENCE:

See Intertek-ATI Report No. G0170.01-201-44, G0170.02-201-44 and G0151.01-201-18 for complete test results.

A copy of this report will be retained by Intertek-ATI for a period of four years. This report is the exclusive property of the client named herein and is applicable to the sample tested. Results obtained are tested values and do not constitute an opinion or endorsement by this laboratory.

ARCHITECTURAL TESTING, INC.

ARCHITECTURAL TESTING, INC.

Eric J. Schoenthaler
Project Manager

Daniel A. Johnson
Director - Regional Operations