



**SUMMARY TEST REPORT**

FOR: Andersen Corporation, E-Series  
2045 Kerper Boulevard  
Dubuque, Iowa 52001

Report Number: G0172.03-201-44  
Test End Date: 07/12/2016  
Report Date: 09/22/2016  
Test Record Retention End Date: 09/22/2020

SERIES TESTED: E-Series Hinged Patio Door Inswing Transom with Harbor Master IG  
MODEL TESTED: 6030

**NAFS-08/-11** Class LC-PG45 1829 x 914 (72 x 36)-TR DP +60/-65 psf

<u>Test</u>	<u>Results Summary</u>
Resistance to Air Infiltration	<0.01 cfm/ft <sup>2</sup> (ASTM E283)
Resistance to Water Penetration	Pass at DP45 (ASTM E547)
Resistance to Structural Loading	Pass at DP +60/-65 (ASTM E330)
Forced Entry Resistance	Pass (ASTM F588)

**ASTM E1886, E1996**

<u>Test</u>	<u>Results Summary</u>
Impact	Wind Zone 4, Missile level D
Pressure Cycling	DP +60/-65 psf

**Dade County Testing**

<u>Test</u>	<u>Results Summary</u>
TAS 202	Pass at DP +60/-65 psf
TAS 201	Pass (Large Missile)
TAS 203	Pass at +60/-65 psf

<b>REFERENCE:</b>	See Intertek-ATI Report No. G0172.01-201-44, G0172.02-201-44 and G0153.01-201-18 for complete test results.
-------------------	---

A copy of this report will be retained by Intertek-ATI for a period of four years. This report is the exclusive property of the client named herein and is applicable to the sample tested. Results obtained are tested values and do not constitute an opinion or endorsement by this laboratory.

**ARCHITECTURAL TESTING, INC.**

**ARCHITECTURAL TESTING, INC.**

Eric J. Schoenthaler  
Project Manager

Daniel A. Johnson  
Director - Regional Operations