

SUMMARY TEST REPORT

FOR: Andersen Corporation Report Number: D4967.03-201-47

71 Second Street Test End Date: 02/27/2014 Strathroy, Ontario N7G 3H8 Report Date: 03/10/2014

Canada Test Record Retention End Date: 03/10/2018

SERIES TESTED:

A-Series Sash Set Specialty Window – Archtop

MODEL TESTED

Aluminum Clad Wood Fixed Window

NAFS-08/-11 Class LC-PG50 Size Tested 125.0 x 75.0 in. DP+50/-50

NAFS-05 N/A

<u>Test</u> <u>Results Summary</u>

Operating Ease N/A

Resistance to Air Infiltration <0.01 cfm/ft2 (ASTM E283)
Resistance to Water Penetration Pass at DP50 (ASTM E547)
Resistance to Structural Loading Pass at DP50 (ASTM E330)
Forced Entry Resistance Pass (ASTM F 588)

CAN/CSA A440-00, Evaluation to the prescriptive requirements were not performed

<u>Test</u>	<u>Rating</u>
Operating Ease	N/A
Air Tightness	Fixed
Water Tightness	В3
Wind Load Resistance	C5
Blow-Out	C3

Test	Results Summary
Impact	(N/A)
Pressure Cycling	(N/A)

REFERENCE:	See ATI Report No. D4967.01-201-47 and D4967.02-201-47 for complete test
	results

A copy of this report will be retained by ATI for a period of four years. This report is the exclusive property of the client named herein and is applicable to the sample tested. Results obtained are tested values and do not constitute an opinion or endorsement by this laboratory.

ARCHITECTURAL TESTING, INC

ARCHITECTURAL TESTING, INC

Karl A. Lips-Eakins Daniel A. Johnson

Senior Technician Director of Regional Operations

849 Western Avenue North St. Paul, MN 55117 Phone: 651-636-3835 Fax: 717-764-4129

www.archtest.com