



SUMMARY TEST REPORT

FOR: Andersen Corporation
100 Fourth Avenue North
Bayport, MN 55003

Report Number: E9924.03-201-47
Test End Date: 07/29/2015
Report Date: 09/25/2015
Test Record Retention End Date: 09/25/2019

SERIES TESTED:
MODEL TESTED

A-Series Casement Window
ACW3060 IG

NAFS-08/-11

Class LC-PG50 Size Tested 35.3 x 71.3 in. DP+50/-50

Test

Results Summary

Ease of Operation
Resistance to Air Infiltration
Resistance to Water Penetration
Resistance to Structural Loading
Forced Entry Resistance

Pass, 14 N (3.0 lbf) max.
<0.01 cfm/ft² (ASTM E283)
Pass at DP50 (ASTM E547)
Pass at DP +50/-50 (ASTM E330)
Pass (ASTM F 588)

CAN/CSA A440-00, Evaluation to the prescriptive requirements were not performed

Test

Rating

Ease of Operation
Air Tightness
Water Tightness
Wind Load Resistance
Blow-Out
Insect Screen Strength
Resistance to Forced Entry

14 N (3.0 lbf)
A3
B3
C3
C3
S1
F10

REFERENCE:

See Intertek-ATI Report No. E9924.01-201-47, and E9924.02-201-47 for complete test results.

A copy of this report will be retained by Intertek-ATI for a period of four years. This report is the exclusive property of the client named herein and is applicable to the sample tested. Results obtained are tested values and do not constitute an opinion or endorsement by this laboratory.

INTERTEK-ATI

INTERTEK-ATI

Karl A. Lips-Eakins
Senior Technician

Daniel A. Johnson
Director - Regional Operations