



SUMMARY TEST REPORT

FOR: Eagle Window & Door, Inc.
 2045 Kerper Boulevard
 Dubuque, Iowa 52001

Report Number: C4400.06-201-44
 Test End Date: 12/13/2012
 Report Date: 12/19/2012
 Test Record Retention End Date: 01/02/2017

SERIES TESTED: Series 13 1-pc Radius Frame Casement Fixed with insulated impact glazing

NAFS-11	Class CW-PG65 1219 x 1829 (48 x 72)-FW*
NAFS-08	Class CW-PG65 1219 x 1829 (48 x 72)-FW*
NAFS-05	FW-C65 1219 x 1829 (48 x 72)*
<i>General Note: An asterisk (*) next to the size designation indicates that the size tested for optional performance was smaller than the Gateway test size for the product type and class. Reference Architectural Testing, Inc. Report No. C4400.01-201-44, dated 01/02/13 for complete Gateway test specimen description and test results.</i>	

<u>Test</u>	<u>Results Summary</u>
Resistance to Air Infiltration	<0.01 cfm/ft ² (ASTM E283)
Resistance to Water Penetration	Pass at DP65 (ASTM E547)
Resistance to Structural Loading	Pass at DP65 (ASTM E330)
Forced Entry Resistance	Pass (ASTM F588)

CAN/CSA A440-00, Evaluation to the prescriptive requirements were not performed

<u>Test</u>	<u>Rating</u>
Air Tightness	Fixed
Water Tightness	B4
Wind Load Resistance	C5
Blow-Out	C4

<u>Test</u>	<u>Results Summary</u>
Impact	Wind Zone 4, Missile D (ASTM E1886 and E1996)
Pressure Cycling	Pass (ASTM E1886)

REFERENCE:	See ATI Report No. C4400.02-201-44, C4400.04-201-44 and C4405.04-18 for complete test results.
-------------------	--

A copy of this report will be retained by ATI for a period of four years. This report is the exclusive property of the client named herein and is applicable to the sample tested. Results obtained are tested values and do not constitute an opinion or endorsement by this laboratory.

ARCHITECTURAL TESTING, INC

ARCHITECTURAL TESTING, INC

Eric J. Schoenthaler
 Project Manager

Daniel A. Johnson
 Director - Regional Operations

849 Western Avenue North
 St. Paul, MN 55117
 Phone: 651-636-3835
 Fax: 651-636-3843
 www.archtest.com