



**SUMMARY TEST REPORT**

FOR: Andersen Corporation  
71 Second Street  
Strathroy, Ontario N7G 3H8  
Canada

Report No.: E1924.02-201-47  
Test End Date: 12/12/2014  
Report Date: 01/08/2015  
Test Record Retention End Date: 12/12/2018

SERIES TESTED: Fixed Door  
MODEL TESTED: Single Outswing Commercial Door, Fixed

ASTM E 330-02 DP +35/-35 psf

**Test**

**Results Summary**

Resistance to Air Infiltration	N/A
Resistance to Water Penetration	N/A
Resistance to Structural Loading	Pass at DP +35/-35 psf (ASTM E330)
Forced Entry Resistance	N/A

**REFERENCE:** See ATI Report No. E1924.01-201-47 for complete test results.

A copy of this report will be retained by ATI for a period of four years. This report is the exclusive property of the client named herein and is applicable to the sample tested. Results obtained are tested values and do not constitute an opinion or endorsement by this laboratory.

**ARCHITECTURAL TESTING, INC**

**ARCHITECTURAL TESTING, INC**

Karl A. Lips-Eakins  
Senior Technician

Daniel A. Johnson  
Director of Regional Operations