



SUMMARY TEST REPORT

FOR: Andersen Corporation
71 Second Street
Strathroy, Ontario N7G 3H8
Canada

Report No.: E1927.02-201-47
Test End Date: 12/11/2014
Report Date: 01/21/2015
Test Record Retention End Date: 12/11/2018

SERIES TESTED: Fixed Door
MODEL TESTED: Double Outswing Commercial Door, Fixed

ASTM E 330-02 DP +35/-35 psf

Test

Results Summary

Resistance to Air Infiltration	N/A
Resistance to Water Penetration	N/A
Resistance to Structural Loading	Pass at DP +35/-35 psf (ASTM E330)
Forced Entry Resistance	N/A

REFERENCE: See ATI Report No. E1927.01-201-47 for complete test results.

A copy of this report will be retained by ATI for a period of four years. This report is the exclusive property of the client named herein and is applicable to the sample tested. Results obtained are tested values and do not constitute an opinion or endorsement by this laboratory.

ARCHITECTURAL TESTING, INC

ARCHITECTURAL TESTING, INC

Karl A. Lips-Eakins
Senior Technician

Daniel A. Johnson
Director of Regional Operations