

## **SUMMARY TEST REPORT**

FOR: Andersen Corporation Report Number: C3706.04-201-47

100 Fourth Avenue North Bayport, MN 55003

Test End Date: 10/29/2012 Report Date: 11/05/2012

Test Record Retention End Date: 11/05/2016

SERIES TESTED:

A-Series Frenchwood Gliding Patio Door

FWGD4380S IG IR

**MODEL TESTED** NAFS-08/-11

NAFS-05

Class LC-PG65 Size Tested 50.4 x 95.5 in. DP+65/-80

N/A

**Test** 

**Results Summary** 

N/A

**Operating Ease** Resistance to Air Infiltration

<0.01 cfm/ft<sup>2</sup> (ASTM E283) Pass at DP70 (ASTM E547)

Resistance to Water Penetration Resistance to Structural Loading

Pass at DP+65/-80 (ASTM E330)

Forced Entry Resistance Pass (ASTM F 588)

**Test** Rating **Operating Ease** N/A Air Tightness А3 Water Tightness **B5** Wind Load Resistance C3 Blow-Out C3

CAN/CSA A440-00, Evaluation to the prescriptive requirements were not performed

**Test Results Summary** Zone 4, Missile D **Impact** Pressure Cycling +70/-80 psf

See ATI Report No. C3706.01-201-47 for complete test results. REFERENCE:

A copy of this report will be retained by ATI for a period of four years. This report is the exclusive property of the client named herein and is applicable to the sample tested. Results obtained are tested values and do not constitute an opinion or endorsement by this laboratory.

ARCHITECTURAL TESTING, INC

ARCHITECTURAL TESTING, INC

Karl A. Lips-Eakins Senior Technician

Daniel A. Johnson

**Director of Regional Operations** 

849 Western Avenue North St. Paul, MN 55117 Phone: 651-636-3835 Fax: 717-764-4129

www.archtest.com