

## PRODUCT PERFORMANCE TEST REPORT

**FOR:** Andersen Corporation REPORT NO.: C0301.03-201-47

100 Fourth Avenue NorthTEST DATE:06/07/12Bayport, Minnesota 55003THROUGH:07/17/12

REPORT DATE: 07/17/12

TEST RECORD RETENTION DATE: 07/17/16

**PRODUCT TESTED:** A-Series Frenchwood Hinged Patio Door-Inswing / FWHID6080AS IG

**TEST METHODS:** AAMA/WDMA/CSA 101/I.S.2/A440-05 and A440-08

Air Infiltration per ASTM E 283 Water Penetration per ASTM E 547 Uniform Load Structural per ASTM E330 Forced Entry Resistance per ASTM F 588

**RATINGS:** Class LC-PG45 Size Tested 71.3" x 95.5" and SHD-LC45 1809 x 2425 (71 x 95)

DP +45/-45 psf

**RESULTS:** 

<u>TEST</u> <u>RESULTS</u> <u>ALLOWED</u>

Air Infiltration

@ 75 Pa (1.57 psf) 0.10 L/s/m<sup>2</sup>  $(0.02 \text{ cfm/ft}^2)$  1.50 L/s/m<sup>2</sup>  $(0.30 \text{ cfm/ft}^2)$ 

Water Penetration

@ 330 Pa (6.75 psf) No Leakage No Leakage

Structural Performance - Mullion

REFERENCE: See ATI Report No. C0301.01-201-47 for complete test results.

A copy of this report will be retained by ATI for a period of four years. This report is the exclusive property of the client so named herein and is applicable to the sample tested. Results obtained are tested values and do not constitute an opinion or endorsement by this laboratory.

ARCHITECTURAL TESTING, INC

ARCHITECTURAL TESTING, INC

Karl A. Lips-Eakins Daniel A. Johnson

Senior Technician Director - Regional Operations

849 Western Avenue North St. Paul, MN 55117 phone: 651-636-3835 fax: 651-636-3843

www.archtest.com