

SUMMARY TEST REPORT

FOR: Andersen Corporation Report Number: D2578.03-201-44

100 Fourth Avenue North Test End Date: 12/19/2013 Bayport, Minnesota 55003 Report Date: 03/07/2014

Test Record Retention End Date: 01/31/2018

A-Series Frenchwood Hinged Patio Door-Inswing with Stormwatch SERIES TESTED:

Protection/FWHID64611AP DPUP IG IR Hinged Inswing Wood Door (XX)

Class LC-PG65 Size Tested 75.5" x 82.4" NAFS-08/-11

DP+65/-80*

Test Results Summary

Operating Ease Pass, 40 N (9 lbf) max. Resistance to Air Infiltration 0.04 cfm/ft² (ASTM E283) Resistance to Water Penetration Pass at DP65 (ASTM E547) Pass at DP65 (ASTM E330) Resistance to Structural Loading Forced Entry Resistance Pass (AAMA 1304)

CAN/CSA A440-00, Evaluation to the prescriptive requirements were not performed

Test Rating 40 N (9 lbf) max. **Operating Ease** Air Tightness A3 **B4** Water Tightness Wind Load Resistance C3 Blow-Out C3

Test Results Summary Impact No rips, tears or penetrations Pressure Cycling DP+65/-80

REFERENCE:	See ATI Report No. D2578.01-201-44, D2578.02-201-44 and D2578.04-201-44
	for complete test results. Reference Architectural Testing, Inc. Report No.
	D2580.01-201-44 dated 01/31/14 for complete <i>Gateway</i> test specimen
	description and test results.

A copy of this report will be retained by ATI for a period of four years. This report is the exclusive property of the client named herein and is applicable to the sample tested. Results obtained are tested values and do not constitute an opinion or endorsement by this laboratory.

ARCHITECTURAL TESTING, INC

ARCHITECTURAL TESTING, INC

Tony D. Gavin Technician

MODEL TESTED

Daniel A. Johnson

Director - Regional Operations

849 Western Avenue North St. Paul, MN 55117 Phone: 651-636-3835 Fax: 717-764-4129

www.archtest.com