

SUMMARY TEST REPORT

FOR: Andersen Corporation Report Number: D2580.03-201-44

100 Fourth Avenue North Test End Date: 11/11/2013 Report Date: 03/07/2014 Bayport, Minnesota 55003

Test Record Retention End Date: 01/31/2018

A-Series Frenchwood Hinged Patio Door-Inswing with Stormwatch SERIES TESTED:

Protection/FWHID6480AP DPUP IG IR MODEL TESTED Hinged Inswing Wood Door (XX)

Class LC-PG65 Size Tested 75.25" x 95.5" NAFS-08/-11

DP+65/-70

Test Results Summary

Operating Ease Pass, 40 N (9 lbf) max. <0.01 cfm/ft² (ASTM E283) Resistance to Air Infiltration Resistance to Water Penetration Pass at DP65 (ASTM E547) Pass at DP65 (ASTM E330) Resistance to Structural Loading Pass (AAMA 1304) Forced Entry Resistance

CAN/CSA A440-00, Evaluation to the prescriptive requirements were not performed

Test Rating 40 N (9 lbf) max. **Operating Ease** Air Tightness A3 Water Tightness **B4** Wind Load Resistance C3 Blow-Out C3

Test Results Summary Impact No rips, tears or penetrations **Pressure Cycling** DP+65/-70

REFERENCE:	See ATI Report No. D2580.01-201-44, D2580.02-201-44 and D2580.04-201-44
	for complete test results.

A copy of this report will be retained by ATI for a period of four years. This report is the exclusive property of the client named herein and is applicable to the sample tested. Results obtained are tested values and do not constitute an opinion or endorsement by this laboratory.

ARCHITECTURAL TESTING, INC

ARCHITECTURAL TESTING, INC

Tony D. Gavin Daniel A. Johnson

Technician **Director - Regional Operations**

> 849 Western Avenue North St. Paul, MN 55117 Phone: 651-636-3835 Fax: 717-764-4129

www.archtest.com