

SUMMARY TEST REPORT

FOR: **Andersen Corporation**

100 Fourth Avenue North Bayport, MN 55003

Report Number: C5878.03-201-47

Test End Date: 02/25/2013 Report Date:

04/01/2013

Test Record Retention End Date:

04/01/2017

SERIES TESTED: MODEL TESTED

400 Series Frenchwood Hinged Patio Door - Outswing

FW03180S IG

NAFS-08/-11

Class LC-PG45 Size Tested 35.9 x 95.5 in.

DP+45/-45

Test

Operating Ease Resistance to Air Infiltration

Resistance to Water Penetration Resistance to Structural Loading Forced Entry Resistance

Results Summary N/A

0.01 cfm/ft2 (ASTM E283) Pass at DP45 (ASTM E547) Pass at DP45 (ASTM E330)

Pass (ASTM F 588)

CAN/CSA A440-00, Evaluation to the prescriptive requirements were not performed

<u>Test</u>	<u>Rating</u>
Operating Ease	N/A
Air Tightness	A3
Water Tightness	В3
Wind Load Resistance	C3
Blow-Out	C3

<u>Test</u>	Results Summary
Impact	(N/A)
Pressure Cycling	(N/A)

REFERENCE:	See ATI Report No. C5878.01-201-47 for complete test results.

A copy of this report will be retained by ATI for a period of four years. This report is the exclusive property of the client named herein and is applicable to the sample tested. Results obtained are tested values and do not constitute an opinion or endorsement by this laboratory.

ARCHITECTURAL TESTING, INC

ARCHITECTURAL TESTING, INC

Karl A. Lips-Eakins Senior Technician

Daniel A. Johnson

Director of Regional Operations

849 Western Avenue North St. Paul, MN 55117 Phone: 651-636-3835 Fax: 717-764-4129

www.archtest.com