

SUMMARY TEST REPORT

1010	indersen dorporation	Report Rumber.	
	100 Fourth Avenue North	Test End Date:	05/28/2013
	Bayport, MN 55003	Report Date:	07/10/2013
		Test Record Retention End Date:	
SERIES	TESTED:	100 Series Gliding Window	
MODEL TESTED		100GX06060 IG	
NAFS-08/-11		Class LC-PG30 Size Tested 71.5 x 71.5 in. DP+30/-30	
NAFS-05		N/A	
<u>Test</u>		<u>Results Summary</u>	
Operating Ease		36 N (8 lbf)	
Resistance to Air Infiltration		0.03 cfm/ft ² (ASTM E283)	
Resistance to Water Penetration		Pass at DP30 (ASTM E547)	
Resistance to Structural Loading		Pass at DP30 (ASTM E330)	
Forced Entry Resistance		Pass (ASTM F 588)	
CAN/C	SA A440-00 , Evaluation to the prescriptive	ve requirements were not performed	
<u>Test</u>		Rating	
Operating Ease		N/A	
Air Tightness		A3/F	
Water Tightness		B2	
Wind Load Resistance		C1	
Blow-0	ut	C2	
<u>Test</u>	st Results Summary		
Impact		(N/A)	
Impact			

REFERENCE:	See ATI Report No. C9044.01-201-47 and C9044.02-201-47	
REFERENCE.	for complete test results	

A copy of this report will be retained by ATI for a period of four years. This report is the exclusive property of the client named herein and is applicable to the sample tested. Results obtained are tested values and do not constitute an opinion or endorsement by this laboratory.

ARCHITECTURAL TESTING, INC

ARCHITECTURAL TESTING, INC

Report Number: C9044.03-201-47

Karl A. Lips-Eakins Senior Technician

FOR:

Andersen Corporation

Daniel A. Johnson Director of Regional Operations

849 Western Avenue North St. Paul, MN 55117 Phone: 651-636-3835 Fax: 717-764-4129 www.archtest.com