

## **SUMMARY TEST REPORT**

FOR: Andersen Corporation Report Number: C3151.03-201-47

100 Fourth Avenue North Test End Date: 11/07/2012

Bayport, MN 55003 Report Date: 11/14/2012

Test Record Retention End Date: 11/14/2016

SERIES TESTED: 200 Series Gliding Window MODEL TESTED 244GW6050 IG

NAFS-08/-11 Class R PG20 Size Tested 71.5 x 59.5 in.

DP+20/20 N/A

Test Results Summary

Operating EasePass, less than 19 lbsResistance to Air Infiltration0.21 cfm/ft² (ASTM E283)Resistance to Water PenetrationPass at DP20 (ASTM E547)Resistance to Structural LoadingPass at DP20 (ASTM E330)Forced Entry ResistancePass (ASTM F 588)

CAN/CSA A440-00, Evaluation to the prescriptive requirements were not performed

<u>Test</u>	<u>Rating</u>
Operating Ease	Pass
Air Tightness	A2
Water Tightness	B1
Wind Load Resistance	C1
Blow-Out	C1

Test	Results Summary
Impact	(N/A)
Pressure Cycling	(N/A)

## **REFERENCE:** See ATI Report No. C3151.01-201-47 for complete test results.

A copy of this report will be retained by ATI for a period of four years. This report is the exclusive property of the client named herein and is applicable to the sample tested. Results obtained are tested values and do not constitute an opinion or endorsement by this laboratory.

ARCHITECTURAL TESTING, INC

NAFS-05

ARCHITECTURAL TESTING, INC

Karl A. Lips-Eakins Daniel A. Johnson

Senior Technician Director of Regional Operations

849 Western Avenue North St. Paul, MN 55117 Phone: 651-636-3835 Fax: 651-636-3843

www.archtest.com