



SUMMARY TEST REPORT

FOR: Andersen Corporation
100 Fourth Avenue North
Bayport, MN 55003

Report Number: E1934.03-201-47
Test End Date: 10/29/2014
Report Date: 02/20/2015
Test Record Retention End Date: 10/29/2018

SERIES TESTED: 200 Series Narroline Gliding Patio Door/NLGD60611AS IG
MODEL TESTED: Sliding Door

NAFS-08/-11

Class LC-PG40 Size Tested 71.3 x 82.4 in.*
DP +40/-40

Test

Results Summary

Operating Force
Resistance to Air Infiltration
Resistance to Water Penetration
Resistance to Structural Loading
Forced Entry Resistance

Pass, 22 N (5.0 lbf) max.
0.05 cfm/ft² (ASTM E283)
Pass at DP40 (ASTM E547)
Pass at DP40 (ASTM E330)
Pass (ASTM F 842)

CAN/CSA A440-00, Evaluation to the prescriptive requirements were not performed

Test

Rating

Ease of Operation
Air Tightness
Water Tightness
Wind Load Resistance
Blow-Out
Resistance to Forced Entry

36 N (8 lbf)
A3
B2
C2
C2
F10

REFERENCE:

See ATI Report No. E1934.01-201-47 and E1934.02-201-47 for complete test results. Reference Architectural Testing, Inc. Report No. E1937.01-201-47, dated 11/12/14 for complete *Gateway* test specimen description and test results.

A copy of this report will be retained by ATI for a period of four years. This report is the exclusive property of the client named herein and is applicable to the sample tested. Results obtained are tested values and do not constitute an opinion or endorsement by this laboratory.

ARCHITECTURAL TESTING, INC

ARCHITECTURAL TESTING, INC

Karl A. Lips-Eakins
Senior Technician

Daniel A. Johnson
Director - Regional Operations