



SUMMARY TEST REPORT

FOR: Andersen Corporation

100 Fourth Avenue North Bayport, MN 55003 Report Number: E6559.03-201-47 Test End Date: 04/01/2015

Report Date: 04/10/2015

Test Record Retention End Date: 04/10/2019

SERIES TESTED: 200 Series Gliding Patio Door MODEL TESTED PSGPD81611AS DPUP IG

NAFS-08/-11 Class LC-PG40 Size Tested 96.0 x 82.4 in. DP+40/-40

<u>Test</u> <u>Results Summary</u>

Operating Force18 N (4 lbf) max.Resistance to Air Infiltration0.13 cfm/ft² (ASTM E283)Resistance to Water PenetrationPass at DP40 (ASTM E547)Resistance to Structural LoadingPass at DP40 (ASTM E330)Forced Entry ResistancePass (ASTM F842)

CAN/CGSB-82.1-M89, Evaluation to the prescriptive requirements were not performed

TestRatingOperating Force18 N (4 lbf) max.Air TightnessA2Water TightnessB1Wind Load ResistanceC1Blow-OutC3

REFERENCE:	See Intertek-ATI R	Report No.	E6559.01-201-47	and	E6559.02-201-47	for
	complete test results.					

A copy of this report will be retained by Intertek-ATI for a period of four years. This report is the exclusive property of the client named herein and is applicable to the sample tested. Results obtained are tested values and do not constitute an opinion or endorsement by this laboratory.

INTERTEK-ATI INTERTEK-ATI

Karl A. Lips-Eakins Daniel A. Johnson

Senior Technician Director - Regional Operations