

SUMMARY TEST REPORT

FOR: Andersen Corporation 71 Second Street Strathroy, Ontario N7G 3H8 Canada	Report Number: D4969.03-201-47 Test End Date: 02/27/2014 Report Date: 03/10/2014 Test Record Retention End Date: 03/10/2018
SERIES TESTED:	A-Series Sash Set Specialty Window – Springline
MODEL TESTED	Aluminum Clad Wood Fixed Window
NAFS-08/-11	Class LC-PG50 Size Tested 125.0 x 75.0 in. DP+50/-50
NAFS-05	N/A
<u>Test</u>	<u>Results Summary</u>
Operating Ease	N/A
Resistance to Air Infiltration	<0.01 cfm/ft ² (ASTM E283)
Resistance to Water Penetration	Pass at DP50 (ASTM E547)
Resistance to Structural Loading	Pass at DP50 (ASTM E330)
Forced Entry Resistance	Pass (ASTM F 588)
CAN/CSA A440-00, Evaluation to the prescriptive requirements were not performed	
<u>Test</u>	Rating
Operating Ease	N/A
Air Tightness	Fixed
Water Tightness	B3
Wind Load Resistance	C5
Blow-Out	C3
<u>Test</u>	Results Summary
Impact	(N/A)
Pressure Cycling	(N/A)
	See ATI Report No. D4969 01-201-47 and D4969 02-201-47 for complete test

REFERENCE:	See ATI Report No. D4969.01-201-47 and D4969.02-201-47 for complete test results.
------------	---

A copy of this report will be retained by ATI for a period of four years. This report is the exclusive property of the client named herein and is applicable to the sample tested. Results obtained are tested values and do not constitute an opinion or endorsement by this laboratory.

ARCHITECTURAL TESTING, INC

ARCHITECTURAL TESTING, INC

Karl A. Lips-Eakins Senior Technician Daniel A. Johnson Director of Regional Operations

849 Western Avenue North St. Paul, MN 55117 Phone: 651-636-3835 Fax: 717-764-4129 www.archtest.com